RRR. Haul road and access road SSS. Coal truck unloading grating TTT. Two Helper cooling towers

Limitations and Tests Procedures

9. Emissions to the atmosphere at all times from the indicated emission points shall not exceed the following rates and concentrations:

A.

Each Main Boiler Stack

Before the Modification (While Rated at 8,500 x 106 Btu/hr)

| Pollutant | lb/ 106 Btu heat input | |
|------------------|------------------------|--|
| PM ₁₀ | 0.020* | lb/ 106 Btu heat input |
| SO ₂ | 0.15** | 1b/ 10 ⁶ Btu heat input based on 30-day rolling-average |
| | | 10.0 % of the potential combustion concentration |
| NO _x | 0.50** | lb/ 106 Btu heat input based on 30-day rolling-average |

After the Modification (While Rated at 9,225 x 106 Btu/hr)

| Pollutant | lb/ 10° Btu heat in | put |
|------------------|---------------------|--|
| PM ₁₀ | 0.0184 * | lb/ 106 Btu heat input |
| SO ₂ | 0.138 ** | lb/ 10 ⁶ Btu heat input based on 30-day rolling-average |
| | | 10.0 % of the potential combustion concentration |
| NO _x | 0.461** | lb/ 10 ⁶ Btu heat input based on 30-day rolling-average |

B. Testing Status (To be applied above)

Dust Collectors

Engineering Review: Modification to DAQE-749-01 to Increase Power Generation November 15, 2001 Page 17

^{*} Equivalency shall be determined by the Executive Secretary.

^{*} Test once a year. The Executive Secretary may require testing at any time.

^{**}Compliance for NO_x and SO₂ emissions shall be demonstrated through use of a continuous emissions monitoring system as outlined in Condition 24.